

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
2821-CPR-0273

Issue date
28-Feb-2024

Issue No.
4

Re-Issue date
04-Mar-2025



In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer:
Transom Post OpCo LLC DBA Bose Professional

Address:
117 South St, Hopkinton, MA 01748

Product:
AMU108 and AMU108-120 ArenaMatch Utility Loudspeaker

Places of production:
Factory A

Harmonized Standard: EN 54-24: 2008
Product Area: 10

Head of Notified Body:

Erik Teubler
Issued by UL International (Netherlands) B.V., Notified Body 2821.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standard(s) under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Economic Operators:

Manufacturer: Transom Post OpCo LLC DBA Bose Professional
Manufacturers Address: 117 South St, Hopkinton, MA 01748
Authorised Representative: Transom Post NETHERLANDS BV
Authorised Representative Address: Keizersgracht 391 A
1016EJ Amsterdam

Detailed information sheet:

Product Reference: Model AMU108 and AMU108-120 Loudspeaker
Type: Type B (Outdoor) IP33C
Description: Loudspeaker for voice alarm systems for fire detection and fire alarm systems
Key Performance parameters: Operating Voltage: 100V / 70V Audio Line
Wattage: 70 Vrms: 5W, 10W, 20W, 40W, 80W
100 Vrms: 10W, 20W, 40W, 80W
8Ω Direct: 200W
Accessories: NA
Identification and intended use Product: Loudspeaker for voice alarm systems for fire detection and fire alarm systems.
Intended use: Fire safety.

Limitations on the acceptance or use of the product(s):

Installation instructions To be used in accordance with the supplier's installation instructions, and technical datasheet.
UL Report: NC34657-D02-EuropeanDirective-Original

Revision Table:

Version	Project Number	Date	Description
1.0	4791122418	28-02-2024	Initial
2.0	4791294381	12-07-2024	Manufacturer address has changed
3.0	4791348322	09-08-2024	New Model Added
4.0	01734312	04-03-2025	Typo correction for maximum wattage

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed or detailed within the technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE