



4705



UKCA CERTIFICATE

APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1018


This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: BOSE CORPORATION
Address: The Mountain Framingham, Ma, 01701 US
Product Description: ArenaMatch Utility Loudspeaker
Model Reference: AMU206 Loudspeaker
Places of production: Factory A
UK Assessment Document(s) & UKTA: EN 54-24: 2008 - Components of voice alarm systems - Loudspeakers

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standards, under system 1/1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the UK Assessment Document/UK Technical Assessment, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

Date of 1st issue: 21 December 2021
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Miles
Head of Approved Body



4705



UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1018

Detailed information sheet

Model Reference: AMU206
Type: Type B (Outdoor) IP33C
Description: Loudspeaker for voice alarm systems for fire detection and fire alarm systems
Operating Voltage: 100V / 70V Audio Line
Wattage: 70 Vrms: 5W, 10W, 20W, 40W, 80W
100 Vrms: 10W, 20W, 40W, 80W
8Ω Direct: 250W

Technical documentation:

UL Report: NC31202-D02-EUROPEAN DIRECTIVE-ORIGINAL

Limitations on the acceptance or use of the product(s):


Installation instructions To be used in accordance with the suppliers installation instructions, and technical datasheet.

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1st issue: 21 December 2021
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Miles
Head of Approved Body

Page 2 of 2