

## **DECLARATION OF PERFORMANCE**

ACCORDING TO CONSTRUCTION PRODUCTS (EU EXIT) REGULATIONS 2020

NO. 811108

| U | Κ |
|---|---|
| C | A |

| 1. Unique identification code of the product-type   |             | AMU108  |
|---|-------------|---|
| 2. Identification of the product  |             | ArenaMatch Utility AMU108   |
| 3. Intended use   |             | Loudspeaker for voice alarm systems for fire detection and fire alarm systems   |
| 4. Name, registered trade name or trade mark and contact address of the manufacturer  |             | Brand: Bose Professional<br>Transom Post OpCo LLC<br>117 South Street<br>Hopkinton, MA 01748-2206 USA   |
| 5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks in Article 12 (2) |             | Transom Post Netherlands UK<br>Squires House 205a High Street,<br>West Wickham, BR4 0PH   |
| <ol> <li>System of assessment and verification of<br/>constancy of performance of the construction<br/>products:</li> </ol>     |             | System 1  |
| 7. Performance of the notified body as required<br>in the harmonised standards  |             | UL(UK) (ID 0843) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued certificate of constancy of performance/certificate of conformity |
| Number of issued certificate of constancy of performance/certificate of conformity  |             | 0843-CPR-1326   |
| 8. European Technical Assessment  |             | No technical assessment has been issued.  |
|   |             | stics and the corresponding performance for the intended use or uses ribed in EN mentioned in the following table   |
| Essential Characteristics   | Performance | Harmonized technical specification EN 54-24: April 2008   |
| Performance under fire condition  | Pass        | 4.2, 5.2, 5.3, 5.4, 5.5   |
| Operational reliability   | Pass        | 4.3, 4.4, 4.5, 5.6, 5.18  |
| Durability of operational reliability:  |             |   |
| Temperature resistance  | Pass        | 5.7, 5.8, 5.9   |
| Humidity resistance   | Pass        | 5.10, 5.11, 5.12  |
| Corrosion resistance  | Pass        | 5.13  |
|   |             |   |

5/17/2024

Date

Transom Post OpCo LLC, 117 South Street, Hopkinton, MA 01748-2206 USA Jero Stark

Jason Karby Manager, System Validation and Compliance Engineering

This declaration of performance is issued under the sole responsibility of the manufactured identified in point 4.