

DECLARATION OF PERFORMANCE



ACCORDING TO CONSTRUCTION PRODUCT REGULATION EU NO. 305/2011 NO. 841029

Unique identification code of the product-type		FreeSpace FS2P Pendant-Mount loudspeaker
Identification of the product		FreeSpace FS2P Pendant-Mount loudspeaker
3. Intended use		Loudspeaker for voice alarm systems for fire detection and fire alarm systems
4. Name, registered trade name or trade mark and contact address of the manufacturer		Brand: Bose Professional Transom Post OPCO LLC 117 South Street Hopkinton, MA 01748-2206 USA
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks in Article 12 (2)		Transom Post NETHERLANDS BV Keizersgracht 391 A 1016EJ Amsterdam The Netherlands
6. System of assessment and verification of constancy of performance of the construction products:		System 1
7. Performance of the notified body as required in the harmonised standards		UL(NL) (ID 2821) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued certificate of constancy of performance/certificate of conformity
Number of issued certificate of constancy of performance/certificate of conformity		2821-CPR-0281
8. European Technical Assessment		No technical assessment has been issued.
9. Declared performance:		
All requirements including all Essei indicated in item 3 have been deter	ntial Characteris mined as descr	stics and the corresponding performance for the intended use or uses ribed in EN mentioned in the following table
Essential Characteristics	Performance	Harmonized technical specification EN 54-24: April 2008
Performance under fire condition	Pass	4.2, 5.2, 5.3, 5.4, 5.5
Operational reliability	Pass	4.3, 4.4, 4.5, 5.6, 5.18
Durability of operational reliability:		
Temperature resistance	Pass	5.7, 5.8, 5.9
Humidity resistance	Pass	5.10, 5.11, 5.12
Corrosion resistance	Pass	5.13
Impact and vibration resistance	Pass	5.14, 5.15, 5.16, 5.17
	L	I .

8/20/2024

Date

Transom Post OPCO LLC, 117 South Street, Hopkinton, MA 01748-2206 USA Jason Karby
Manager, System Validation and
Compliance Engineering

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufactured identified in point 4.