

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**Certificate No.**  
**2821-CPR-0274**

**Issue date**  
28-02-2024

**Issue No.**  
2

**Re-Issue date**  
12-07-2024



In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

**Manufacturer:**  
Transom Post OpCo LLC DBA Bose Professional

**Address:**  
117 South St, Hopkinton, MA 01748

**Product:**  
AMU206 ArenaMatch Utility Loudspeaker

**Places of production:**  
Factory A

**Harmonized Standard: EN 54-24: 2008**  
**Product Area: 10**

Head of Notified Body:

  
Erik Teubler

Issued by UL International (Netherlands) B.V., Notified Body 2821.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standard(s) under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

### Economic Operators:

Manufacturer: Transom Post OpCo LLC DBA Bose Professional  
Manufacturers Address: 117 South St, Hopkinton, MA 01748  
Authorised Representative: Transom Post NETHERLANDS BV  
Authorised Representative Address: Keizersgracht 391 A  
1016EJ Amsterdam

### Detailed information sheet:

Product Reference: Model AMU206 Loudspeaker  
Type: Type B (Outdoor) IP33C  
Description: Loudspeaker for voice alarm systems for fire detection and fire alarm systems  
Key Performance parameters: Operating Voltage: 100V / 70V Audio Line  
Wattage: 70 Vrms: 5W, 10W, 20W, 40W, 80W  
100 Vrms: 10W, 20W, 40W, 80W  
8Ω Direct: 100W  
Accessories: NA  
Identification and intended use Product: Loudspeaker for voice alarm systems for fire detection and fire alarm systems.  
Intended use: Fire safety.

### Limitations on the acceptance or use of the product(s):

Installation instructions To be used in accordance with the supplier's installation instructions, and technical datasheet.  
UL Report: NC34657-D02-EuropeanDirective-Original

### Revision Table:

Version	Project Number	Date	Description
1.0	4791122418	28-02-2024	Initial
2.0	4791294381	12-07-2024	Manufacturer address has changed

**Terms and Conditions:**

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed or detailed within the technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE