

EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon Wade Rd, Basingstoke RG24 8AH, United Kingdom

Certificate of constancy of performance 0843–CPR–0550

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Model FreeSpace FS2C - In-ceiling Loudspeaker

placed on the market under the name or trade mark of

BOSE CORPORATION The Mountain Framingham, Ma, 01701 US

and produced in the manufacturing plant(s)

FACTORY B

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-24: 2008 - Components of voice alarm systems - Loudspeakers

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2020-06-09 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body

2020-06-09

Chris Miles Head of Notified Body UL International (UK) Ltd Page 1 of 3



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon Wade Rd, Basingstoke RG24 8AH, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0550

Product/Device description:

Model FreeSpace FS2C - In-ceiling Loudspeaker

Applicant designation:

Bose Corporation, The Mountain Framingham, Ma, 01701 US

Product Information:

Model Reference: FS2C

Type: Type A (Indoor) IP21C

Description: Loudspeaker for voice alarm systems for fire detection and fire alarm systems

Impedance: $16\Omega / 16W$

Operating Voltage: 100V / 70V Audio Line

Wattage: 70 Vrms: 1W, 2W, 4W, 8W, 16W;

100 Vrms: 2W, 4W, 8W, 16W

Equaliser: PEQ 1 / Freq: 10900 Hz / Gain: -12.0 dB / Q/BW: 10/0.144

Installation instructions:

To be used in accordance with the suppliers installation instructions, and technical datasheet.

CPR report reference:

NC31202-D03-EuropeanDirective-Original

The referenced product complies with all the relevant requirements as per EN54-24: 2008

2020-06-09

Chris Miles Head of Notified Body UL International (UK) Ltd Page 2 of 3



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon Wade Rd, Basingstoke RG24 8AH, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0550

Model: FS2C

| Essential Characteristics | | Performance | Standard |
|---------------------------|----------------------------------------------------|------------------------------|---------------|
| | Performance under | fire condition | |
| 4.2 | Frequency response limits | Pass | EN54-24:2008 |
| 5.2 | Reproducibility (frequency response / sensitivity) | Pass | EN54-24:2008 |
| 5.3 | Rated impedance | Pass | EN54-24:2008 |
| 5.4 | Horizontal and vertical coverage angles | Pass | EN54-24:2008 |
| 5.5 | Maximum sound pressure level | Pass | EN54-24:2008 |
| | Operational r | eliability | |
| 4.3 | Durability | Pass | EN54-24:2008 |
| 4.4 | Construction | Pass | EN54-24:2008 |
| 4.5 | Marking and data | Pass | EN54-24:2008 |
| 5.6 | Rated noise power (durability) | Pass | EN54-24:2008 |
| 5.18 | Enclosure protection | Pass | EN54-24:2008 |
| | Durability of operational reliabili | ty: Temperature Resistance | , |
| 5.7 | Dry heat (operational) | Pass | EN54-24:2008 |
| 5.8 | Dry heat (endurance) | N/A | EN54-24:2008 |
| 5.9 | Cold (operational) | Pass | EN54-24:2008 |
| | Durability of operational reliabi | lity: Humidity Resistance | |
| 5.10 | Damp heat, cyclic (operational) | Pass | EN54-24:2008 |
| 5.11 | Damp heat, steady state (endurance) | Pass | EN54-24:2008 |
| 5.12 | Damp heat, cyclic (endurance) | N/A | EN54-24:2008 |
| | Durability of operational reliabi | lity, corrosion resistance | |
| 5.13 | Sulfur dioxide (SO ₂) Corrosion | Pass | EN54-24:2008 |
| | Durability of operational reliability: in | npact and vibration resistar | nce |
| 5.14 | Shock (operational) | Pass | EN54-24: 2008 |
| 5.15 | Impact (operational) | Pass | EN54-24:2008 |
| 5.16 | Vibration (operational) | Pass | EN54-24:2008 |
| 5.17 | Vibration (endurance) | Pass | EN54-24:2008 |
| .17 | vibration (endurance) | Pass | EN54-24: 2008 |

2020-06-09

Chris Miles Head of Notified Body UL International (UK) Ltd Page 3 of 3